



Confirmation

Eurofins Product Testing A/S confirms that a sample of an Indoor Carpet Adhesive / Rubber Floor Adhesive with the trade name

UZIN WK 222

supplied b

UZIN Utz AG

showed low VOC contents in a test in accordance with SCAQMD rule 1168 as specified in LEED 2009 credit c4.1 (adhesives and sealants).
VOC contents were below the limit values specified as 50 grams VOC minus water per liters for "Indoor Carpet Adhesives" and 60 grams for "Rubber Floor Adhesives".

The test has been performed in March 2012 (G13944AA). The testing was performed according to ISO 17025:2005.

Volatiles content was calculated by Eurofins.
Water content was determined by Eurofins.
Content of exempt compounds was set to zero.
Solids content was determined by Eurofins.

With this confirmation, product UZIN WK 222 showed fulfillment of the specifications in LEED 2009 credit EQ c4.1 (adhesives and sealants).

20 June 2012

Inge Bondgaard
Chemical engineer

Eurofins Product Testing A/S
Smedeskovvej 38
DK 8464 Galten / Denmark

Tel +45 70 22 42 76
Fax +45 70 22 42 75

www.product-testing.eurofins.com